



FIRE PREVENTION DIVISION
KITCHEN HOOD SUPPRESSION SYSTEM– NFPA 17A
SUBMITTAL CHECKLIST



HOW TO APPLY FOR PERMIT:

<https://ezop.sbcounty.gov/citizenaccess/>

REQUIREMENTS ON PLANS:

These are the minimum general requirements for plan check submittal. Additional requirements may be required upon review.

- Project / Building name, street address and city
- Building number and/or suite (if applicable)
- Name, address, phone number and license number of C-16 contractor with signature.
- Assessor's Parcel Number (APN)
- Scaled or fully dimensioned drawings
- Equipment symbol legend
- Equipment part numbers
- Verify system is UL 300 listed
- Plan view of room and all equipment
- System model and permissible number of flow points
- Description and measurements of appliances to be protected
- Type of fuel or power shut-off device
- Number of nozzles and aggregate flow rate, total flow points and nozzle types identified
- Location of pull station and Class K fire extinguisher

ADDITIONAL REQUIREMENTS

- Manufacturers design manual related to submitted installation