



FIRE PREVENTION DIVISION
RESIDENTIAL SPRINKLER SYSTEMS
MANUFACTURED HOME – NFPA 13D



SUBMITTAL CHECKLIST

HOW TO APPLY FOR PERMIT:

<https://ezop.sbcounty.gov/citizenaccess/>

REQUIREMENTS ON PLANS:

These are the minimum general requirements for plan check submittal. Additional requirements may be required upon review.

- Owner address and phone number
- Project street address and city
- Name, address, phone number and license number of C-16 contractor providing the water supply hydraulic calculations
- Assessor's Parcel Number (APN)
- Scaled or fully dimensioned drawings
- Point of Compass
- Total square footage of structure(s)
- Plot plan details showing the size and location of the meter, underground piping, backflow preventer, fire pump and tank if applicable.
- Hydraulic calculations from water meter to the base of the riser

ADDITIONAL REQUIREMENTS

- HCD approved sprinkler plans
- Flow report dated within six months on water department letterhead
- Residential Fire Letter must be submitted and approved prior to sprinkler submittal.